

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To:** Michael & Donna Malyk  
PO Box 59  
Madden, Alberta, T0M 1L0  
(the “Owner”)

**Re:** The Drinking Water Supply located in Madden, Alberta and municipally described as:

Madden Meats and Foods  
SW 1/4 31-28-02-W5M  
Madden, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The water sample submitted on August 27, 2009, was of unacceptable microbiological quality, namely, the presence Total Coliform bacteria. The water sample submitted on August 31, 2009, was of unacceptable microbiological quality, namely, the presence of Total Coliform bacteria.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The water samples submitted on August 27, 2009 and August 31, 2009, were of unacceptable microbiological quality, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue an Advisory to all users of the Drinking Water Supply for Madden Meats and Foods to boil or treat the water to render it safe for human consumption, or to provide an alternate source of safe drinking water that is approved by

Alberta Health Services, and

2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
  - a. Post signage approved by Alberta Health Services at all water outlets accessible by the public stating that the water is not safe for human consumption.
  - b. Provide hand sanitizer of at least 70% alcohol content at all hand washing sinks for the disinfection of hands after they are washed.
  - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
  - d. Conduct any necessary maintenance work on the drinking water system to render the water safe for human consumption.
  - e. After completion of any maintenance work and/or treatment of the drinking water system, submit water samples, taken at least 24 hours apart, to the Provincial Laboratory of Public Health for microbiological testing.
3. That, until such time as the work referred to in paragraph 2 is completed and the Source of Water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

Dated at Airdrie, Alberta, this 8th day of September, 2009 as follow-up to a verbal order issued on the 3<sup>rd</sup> day of September, 2009.

---

Carol Brittain, BSc, CPHI(C)  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**  
Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**  
Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**  
Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**  
Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**ORDER OF AN EXECUTIVE OFFICER**

**Re: The Drinking Water System Madden Meats and Foods located in Madden, Alberta and municipally described as SW 1/4 31-28-02-W5M, Madden, Alberta**

**Page 3**

---

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)

INACTIVE