

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To:** The Stampede Ranch Ltd.  
**Ross, Gail and Joel Edey**  
Box 176  
Longview, Alberta  
T0L 1H0

**Re:** The Water System located in the Municipal District of Foothills, Alberta and municipally described as:

Stampede Boys Ranch  
NE 1/4 25-17-4 W5M  
Municipal District of Foothills, Alberta

WHEREAS I, an **Executive Officer** of Alberta Health Services Calgary, have inspected the above noted Food Establishment pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Food Establishment which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of total coliform bacteria in the June 1, June 8, June 12 and June 23, 2009 water samples.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Food Regulation, 31/2006 and the Food Retail and Foodservices Code, October 2003 exist in and about the above noted food establishment, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of total coliform bacteria in the June 1, June 8, June 12 and the June 23, 2009 water samples. This is a contravention of Section 17(1)(f)(i) of the Food Regulation, 31/2006.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premise, namely:

- a. Post boil water advisory signs that have been issued by Alberta Health Services Calgary next to all water fixtures that are accessible to the public. These signs must remain in place until the drinking water is deemed safe for human consumption by an executive officer of Alberta Health Services, Calgary.
  - b. Ensure that all food processing and preparation in the kitchen is done with potable water from an approved source or with water that has been boiled for one minute.
  - c. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
  - d. Provide bottles of alcohol based hand sanitizer at the kitchen and washroom sinks.
  - e. Immediately discontinue use of hydrogen peroxide as a disinfectant for the water system.
  - f. Switch to chlorine as a disinfectant for the water system and maintain a free available chlorine concentration of 0.5ppm at the farthest point of the distribution system.
  - g. Submit weekly drinking water samples to the Provincial Laboratory of Alberta.
  - h. Prevent horse access to the pen surrounding the well site.
2. The work referred to in paragraph 1(a) to and including 1(h) must be completed immediately and continue until rescinded by an Executive Officer.

Dated at Okotoks, Alberta, this 23<sup>rd</sup> day of July, 2009 **amended** from the previous Boil Water Order issued on the 12th day of June, 2009.

---

Andrew O'Laney  
Executive Officer  
Alberta Health Services, Calgary

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail***

***to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

INACTIVE