

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Allred's Golf Courses Ltd
240086 Lott Creek Boulevard
Calgary, Alberta
T3Z 2V4

Corix Utilities
428 Moraine Road NE
Calgary, AB
T2A 2P2

Re: The Drinking Water Supply located in Calgary, Alberta and municipally described as:

Elbow Springs Golf Club
240086 Lott Creek Boulevard
Calgary, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water in the distribution system may be unsafe for human consumption as the water treatment system has failed.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water in the distribution system may be unsafe for human consumption as the water treatment system has failed. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner undertake and diligently pursue the completion of the following work in and

about the above noted Drinking Water Supply, namely:

- a. Post boil water advisory signs that have been issued by Alberta Health Services next to all water fixtures that are accessible to the public. These signs are to remain in place until the drinking water is deemed safe for human consumption by an executive officer of Alberta Health Services;
 - b. Ensure that all food processing and preparation in the kitchen is done with potable water from an approved source or with water that has been boiled for 1 minute;
 - c. Ensure that all utensils, counters and food contact surfaces are sanitized using an approved sanitizing step;
 - d. Provide bottles of alcohol based hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed;
 - e. Once water treatment system is restored, flush entire distribution system.
 - f. Submit two sets of bacteriological samples at least 24 hours apart, from three representative locations, once the system has been adequately flushed.
2. The work referred to in paragraph 1 a – d shall be completed immediately and continue until this order is lifted. The work referred to in paragraph 1 e-f shall be completed by **October 20th, 2010**. Until the work in paragraph 1 e - f is completed and the drinking water is shown to be potable to the satisfaction of the undersigned or an executive officer of Alberta Health Service, and until such time as the water samples from paragraph 1 (f) are confirmed to be satisfactory, this order shall remain in effect.

Dated at Calgary Alberta, this 13th day of October 2010, confirming the verbal order issued on the 12th of October.



Tanya MacNeil
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

ORDER OF AN EXECUTIVE OFFICER Re: The Drinking Water System located in Calgary AB

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

INACTIVE