

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To: Mr. Reno Bexte**  
**Hamlet of Mossleigh**  
**Vulcan County,**  
**102 Centre Street,**  
**Vulcan, Alberta**  
**T0L 2B0.**

**Re:** The Drinking Water Supply located in Vulcan County, Alberta and municipally described as:  
  
Hamlet of Mossleigh  
Box 57  
Mossleigh, AB

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water in the distribution system may be unsafe for human consumption as there has been a loss of pressure due to a power outage.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water in the distribution system may be unsafe for human consumption as there has been a loss of pressure due to a power outage. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. The owner/operator immediately issue an Advisory to all users of the Hamlet of Mossleigh

Drinking Water Supply to treat their water by boiling for at least one minute prior to consumption.

2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
  - a. Once drinking water is restored flush entire distribution system.
  - b. Ensure water supply is potable according to the most recent version of the Guidelines for Canadian Drinking Water Quality.
  - c. Submit two sets of bacteriological samples at least 24 hours apart, from three representative locations, once the system has been adequately treated and flushed.
3. That, until such time as the work referred to in paragraph 2 is completed and the drinking water is shown to be potable to the satisfaction of the undersigned or an executive officer of Alberta Health Service, and until such time as the water samples from paragraph 2(c) are confirmed to be satisfactory, this order shall remain in effect.

Dated at Okotoks Alberta, this 15<sup>th</sup> day of April, 2010.

---

Neil Williams  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200

**ORDER OF AN EXECUTIVE OFFICER**

**Re: The Drinking Water System located in the Hamlet of Mossleigh in the MD of Vulcan, Alberta .**

**Page 3**

---

Phone: 403-625-4061  
Fax: 403-625-4062

Phone: 403-335-7292  
Fax: 403-335-7610

Fax: 403-995-2639

Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)

INACTIVE