

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To:** Lone Pine Agricultural Society  
**Jo-anne Hannah, Manager**  
RR 2, Site 4, Box 10  
Didsbury, Alberta T0M 0W0  
(the “**Owner**”)

**Re:** The Drinking Water Supply located in Mountain View County, Alberta and municipally described as:

Lone Pine Community Hall  
SW 16-31-27 W4M  
Mountain View County, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above-noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above-noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in the August 24<sup>th</sup>, 2010, and September 14<sup>th</sup>, 2010, water samples.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in the August 24<sup>th</sup>, 2010, and September 14<sup>th</sup>, 2010, water samples, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states that “Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above-noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. Post boil water advisory signs that have been issued by Alberta Health Services, Calgary Zone, next to all water fixtures that are accessible to the public.
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
  - a. Provide bottles of alcohol-based hand sanitizer at the washroom sinks for use after washing hands.
  - b. Clean and disinfect the well and distribution system.
  - c. Submit to the Provincial Laboratory of Public Health two sets of bacteriological samples at least 24 hours apart once the system has been cleaned, disinfected and flushed, starting one (1) week from disinfection.
3. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, this order shall remain in effect.

Dated at Airdrie, Alberta, this 20th day of September, 2010, confirming the Verbal Order issued on September 16<sup>th</sup>, 2010.

---

Carol Brittain CPHI(C)  
Executive Officer  
Alberta Health Services

**Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.**

**The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.**

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)