

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To:** Peter Huyzer  
236 1<sup>st</sup> Ave  
Cluny, Alberta T0J 0S0

**Re:** The Drinking Water Supply located in Cluny, Alberta and municipally described as:

Pete's Bakery  
236 1<sup>st</sup> Ave  
Cluny, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Bacteriological sample on May 18, 2010 was present for Total Coliforms and Ecoli.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The bacteriological sample collected on May 18, 2010 was present for Total coliforms and Ecoli which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
  - a. Post boil water advisory signs that have been issued by Alberta Health Services next to all water fixtures that are accessible to the public. These signs are to remain in place until the drinking water is deemed safe for human consumption by an executive officer of Alberta Health Services;

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Pete's bakery located in Cluny, Alberta and municipally described as 236 1<sup>st</sup> Ave Cluny, Alberta

- b. Ensure that all food processing and preparation in the kitchen is done with potable water from an approved source or with water that has been boiled for 1 minute;
  - c. Ensure that all utensils, counters and food contact surfaces are sanitized using an approved sanitizing step;
  - d. Provide bottles of alcohol based hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed;
  - e. Submit two satisfactory bacteriological samples at least 24 hours apart..
2. The work referred to in paragraph 1 a – d shall be completed immediately and continue until this order is lifted. Until such time as the work referred to in paragraph 1(e) is completed and the Source of Water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, this order shall remain in effect.
3. That, until such time as the work referred to in paragraph 2 is completed and the Source of Water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

Dated at Strathmore, Alberta, this 20<sup>th</sup> day of May, 2010.

---

Norman Kruesel  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W

**Didsbury**

Didsbury Health Unit  
PO Box 130

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons

**Strathmore**

Public Health Building  
650 Westchester Road

**ORDER OF AN EXECUTIVE OFFICER**

**Re: The Drinking Water System Pete's bakery located in Cluny, Alberta and municipally described as 236 1<sup>st</sup> Ave Cluny, Alberta**

PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)

INACTIVE