

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Springbank Community Church
32242 Township Road 245
Calgary, AB T3Z 2N9
(the “**Owner**”)

Re: The Drinking Water Supply located in Rocky View County, Alberta and municipally described as:

Springbank Community Church
SW 34 24 03 W5M

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The results of consecutive water samples submitted on November 9 and 12, 2010 were of unacceptable microbiological quality, revealing the presence of Total Coliform bacteria.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in about the above noted Drinking Water Supply, namely:

- a. The results of consecutive water samples submitted on November 9 and 12, 2010 were of unacceptable microbiological quality, revealing the presence of Total Coliform bacteria. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue an Advisory to all users of the Drinking Water Supply Springbank Community Church to either boil water for at least one minute prior to consumption or to obtain an approved source of safe drinking water.

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Springbank Community Church located in Rocky View County, Alberta and municipally described as SW 34 24 03 W5M, Rocky View County, Alberta

2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
 - a. Post signage approved by Alberta Health Services at all water outlets accessible by the public stating that the water is not safe for human consumption.
 - b. Provide an approved hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed.
 - c. Conduct any necessary maintenance work on the existing drinking water system to render the water safe for human consumption.
 - d. Submit 2 water samples at least 24 hours apart to the Provincial Laboratory for Public Health (Microbiology) for bacteriological testing.
3. The work referred to in paragraph **2(a) through 2(b)** must be completed immediately.
4. The work referred to in paragraph **2(c) through 2(d)** must be completed by December 16, 2010.
5. That, until such time as the work referred to in paragraph 2 is completed and the Source of Water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, and the results of the samples submitted under **2(d)** are determined to be satisfactory, this order shall remain in effect.

Dated at Calgary, Alberta, this 15th day of November, 2010.

Grace Mar, CPHI(C)
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie
Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400

Banff
Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3

Calgary/Mountain View/Rocky View
Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288

Canmore
Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Springbank Community Church located in Rocky View County, Alberta and municipally described as SW 34 24 03 W5M, Rocky View County, Alberta

Fax: 403-912-8410

Phone: 403-762-2990
Fax: 403-762-5570

Fax: 403-943-8056

Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.calgaryhealthregion.ca/envhealth

INACTIVE