

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: The Wedding Pavillion Inc.
10817 West Valley Road SW
Calgary Alberta T3B 5T2
(the “**Owner**”)

J Bladon, E. Heitman and L. Hesketh
10817 West Valley Road SW
Calgary Alberta T3B 5T2
(the “**Owners**”)

Re: The Drinking Water Supply located in Calgary, Alberta and municipally described as:

Wedding Pavillion
10817 West Valley Road SW
Calgary, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by the presence of total coliform bacteria and Escherichia coli in the December 17, 2010 water sample.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by the presence of total coliform bacteria and Escherichia coli in the December 17, 2010 water sample. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
 - a. Post boil water order signs that have been issued by Alberta Health Services next to all water fixtures that are accessible to the public. These signs must remain in place until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services
 - b. Provide an approved hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed.
 - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute. This includes discontinuing the use of pop/juice fountains and ice machines supplied by the water source in question.
 - d. Ensure that all utensils, counter tops and food contact surfaces are cleaned and sanitized with an approved sanitizing step.
 - e. Clean and disinfect the well, and distribution system.
 - f. Submit two sets of bacteriological samples at least 24 hours apart once the system has been cleaned, disinfected and flushed.
2. The work referred to in Paragraph 1 (a) to (d) is to be completed immediately and shall continue until this order is lifted. The work referred to in Paragraph 1 (e) and (f) shall be completed by January 5, 2011.
3. This order shall remain in effect until the work is completed to the satisfaction of an executive officer and samples submitted under Paragraph 1 (f) demonstrate that the water is potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services.

Dated at Calgary, Alberta, this 20th day of December, 2010 following the verbal order issued on December 19, 2010.

Joan E. Fung
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal

Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.calgaryhealthregion.ca/envhealth