

## ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: **Cameron Crossing School**  
Foothills School Division  
Okotoks, Alberta T0L 1B0  
(the “Owner”)

RE: The Drinking Water Supply located in the Okotoks, Alberta and municipally described as:  
  
Cameron Crossing School  
35 North Railway Street  
Okotoks, Alberta

**WHEREAS** I, an **Executive Officer of Alberta Health Services**, have inspected the above premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of consecutive total coliform bacteria in the September 26, 2011 and October 3, 2011 water samples.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by the presence of consecutive total coliform bacteria in the September 26, 2011 and October 3, 2011 water samples which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

**AND WHEREAS** by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue a Boil Water Advisory to all users of the above noted

Drinking Water Supply.

2. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
  - a. Post boil water advisory signs that have been issued by Alberta Health Services next to all water fixtures that are accessible to the public. These signs are to remain in place until the drinking water is deemed safe for human consumption by an executive officer of Alberta Health Services
  - b. Turn off the water supply to any drinking water fountains on the premises.
  - c. Ensure that all food processing and preparation in the kitchen is done with potable water from an approved source or with water that has been boiled for 1 minute;
  - d. Ensure that all utensils, counters and food contact surfaces are sanitized using an approved sanitizing step;
  - e. Provide bottles of alcohol based hand sanitizer at all hand washing sinks in the washrooms for the disinfection of hands after they are washed;
  - f. Treat and resample the water supply.
3. That, until such time as the work referred to in paragraph 2 and the results from 2(f) are satisfactory to the undersigned, or an executive officer of Alberta Health Services, this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Okotoks, Alberta this 6th day of October, 2011, Alberta and confirming a verbal order issued on October 5, 2011.

Andrew O’Laney - BSc, BEH(AD), CPHI(C)  
Executive Officer  
Environmental Health Officer

**YOU HAVE THE RIGHT TO APPEAL**

**A person who**     **a) is directly affected by a decision of a Regional Health Authority, and**  
                          **b) feels himself aggrieved by the decision**

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at 24<sup>th</sup> Floor, Telus Plaza, 10025 - Jasper Avenue, Edmonton, Alberta, T5J 1S6 Telephone (780) 427-2813.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at (780) 342-0122 or the Public Health Appeal Board (780) 427-2813.

You are advised that all orders remain in effect pending such an appeal

#### HEALTH LEGISLATION, REGULATIONS AND STANDARDS

*Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or [www.qp.gov.ab.ca](http://www.qp.gov.ab.ca).*

*Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7) or [www.qp.gov.ab.ca](http://www.qp.gov.ab.ca).*

*Copies of standards are available by contacting the Health Protection Branch of Alberta Health & Wellness at (780) 427-4518, or by visiting: [www.health.alberta.ca/about/health-legislation.html](http://www.health.alberta.ca/about/health-legislation.html)*

#### **AIRDRIE Regional Health Centre**

604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

#### **BANFF Health Unit**

303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

#### **CALGARY - Southport Atrium**

10101 Southport Road SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

#### **CANMORE Public Health**

#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

#### **CLARESHOLM Public Health**

5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403 625-4061  
Fax: 403-625-4062

#### **COCHRANE Community Health Centre**

60 Grande Boulevard  
Cochrane, AB T4C 0S4  
Phone: 403-851-6000  
Fax: 403-851-6009

#### **OKOTOKS Health and Wellness Centre**

11 Cimarron Common  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

#### **STRATHMORE Public Health Office**

650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244