

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To:** Madrina's Ristorante Ltd.  
Box 1094  
Bragg Creek, Alberta T0L 0K0  
(the "**Owner**")

Pavel Krupicka  
Box 1094  
Bragg Creek, Alberta T0L 0K0  
(the "**Owner**")

**Re:** The drinking water supply located in Bragg Creek, Alberta and municipally described as:

Madrina's Ristorante  
26 Balsam Avenue  
Bragg Creek, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The water sample collected on June 6, 2011 revealed the presence of Total Coliforms and E.coli.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Food Regulation, Alberta Regulation 31/2006, and Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The water sample collected on June 6, 2011 revealed the presence of Total Coliforms and E.coli. which is in contravention of the Food Regulation Section 17(1)(f)(i), which states "An operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial food establishment".
- b. The water sample collected on June 6, 2011 revealed the presence of Total Coliforms and E.coli. which is in contravention of the Nuisance and General

Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted source of water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
  - a. Post signage approved by Alberta Health Services at all water outlets accessible by the public stating that the water is not safe for human consumption.
  - b. Provide an approved hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed.
  - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for at least one minute. This includes discontinuing the use of pop/juice fountains and ice machines supplied by the water source in question.
  - d. Ensure that all utensils, counter tops and food contact surfaces are cleaned and sanitized with an approved sanitizing step.
  - e. Conduct any necessary maintenance work on the existing drinking water system to rend the water safe for human consumption.
  - f. Submit a water sample to the Provincial Laboratory for Public Health (Microbiology) for bacteriological testing.
2. The work referred to in paragraph 1(a) through 1(d) must be completed immediately.
3. The work referred to in paragraph 1(e) through 1(f) must be completed by June 16, 2011.
4. That, until such time as the work referred to in paragraph 1 is completed and the source of water is shown to be potable and the sample from paragraph 1(f) is satisfactory to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Madrina's Ristorante located in Bragg Creek, Alberta and municipally described as 26 Balsam Avenue, Bragg Creek, Alberta

---

Dated at Cochrane, Alberta, this 9<sup>th</sup> day of June, 2011, confirming a verbal order issued on the 8<sup>th</sup> day of June, 2011.

---

Grace Mar, CPHI(C)  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)