

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Oxbow Country Golf Course
3150 - 114 Avenue SE
Calgary, Alberta T2Z 3V6

Oxbow Golf Ltd.
3150 - 114 Avenue SE
Calgary, Alberta T2Z 3V6

Telsec Property Corporation
3150 - 114 Avenue SE
Calgary, Alberta T2Z 3V6

Re: The Drinking Water Supply located in Wheatland County, Alberta and municipally described as:

Oxbow Country Golf Course
NE 21-24-25 W4M
Wheatland County, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The well pit is full of water and the water is approaching the well head cap.
- b. Water supplying the premises may be unsafe for human consumption as indicated by the presence of Total Coliforms in the May 11, 2011 water sample.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The well pit is full of water and the water is approaching the well head cap.
- b. Water supplying the premises may be unsafe for human consumption as indicated by the presence of Total Coliforms in the May 11, 2011 water sample.

This is in contravention of the Nuisance and General Sanitation Regulation Section 11.

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Oxbow Country Gold Course located in Wheatland County, Alberta and municipally described as NW 21-24-25-W4M Wheatland County, Alberta.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue an Advisory to all users of the Drinking Water Supply of Oxbow Country Golf Course to boil or treat the water to render it safe for human consumption, or to provide an alternate source of safe drinking water that is approved by Alberta Health Services, and
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
 - a. Post boil water advisory signs next to all water fixtures that are accessible to the public. These signs must remain in place until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - b. Provide potable water from an approved source or provide water that has been boiled for one minute to patrons or staff until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - c. Provide hand sanitizer of at least 60% alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - d. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
 - e. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - f. Ensure that after hand washing, food handlers are disinfecting hands with an alcohol based hand sanitizer of at least 60% alcohol content.
 - g. Conduct any necessary maintenance work on the drinking water system to render the water safe for human consumption.
 - h. Submit 2 water samples at least 24 hours apart to the Provincial Laboratory for Public Health (Microbiology) for bacteriological testing.
3. The work referred to in **paragraph 2(a) – 2(f)** must be completed immediately and continue until rescinded by an Executive Officer.
4. That, until such time as the work referred to in **paragraph 2(g)** is completed and the samples from **2(h)** are shown satisfactory and the Source of Water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System Oxbow Country Gold Course located in Wheatland County, Alberta and municipally described as NW 21-24-25-W4M Wheatland County, Alberta.

Dated at Strathmore, Alberta, this 13th day of May, 2011 confirming the verbal order issued on the 11th day of May, 2011.

Norman Kruesel CPHI(C)
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.calgaryhealthregion.ca/envhealth