

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

**To: Square Butte Ranches Ltd
Condominium Corporation
Plan No.9710379
Site 3 Box 18 RR 1
Millarville, Alberta
T0L 1K0**

**Corix Utilities
428 Moraine Road NE
Calgary, AB
T2A 2P2**

Re: The Drinking Water Supply located at Square Butte Ranch, Alberta and municipally described as:

Square Butte Ranches Ltd
Municipal District of Foothills, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Water in the distribution system may be unsafe for human consumption as there has been a loss of pressure due to a treated water line break.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003, exists in and about the above noted Drinking Water Supply, namely:

- a. Water in the distribution system may be unsafe for human consumption as there has been a loss of pressure due to a treated water line break. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **Unfit for Human Consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. Once water pressure is restored, the owner/operator immediately issue an Advisory to all users of the Square Butte Ranch Water Supply to treat their water by boiling for at least one minute prior to consumption or to use an alternate potable water source.
2. That the Owner/operator undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
 - a. Once the water line break is repaired and pressure is restored, flush the entire distribution system.
 - b. Submit two sets of bacteriological samples at least 24 hours apart, from representative locations, once the system has been adequately flushed.
3. Until such time as the water samples from paragraph 2(b) are confirmed to be satisfactory, and the work in paragraph 2(a) is completed and the drinking water is shown to be potable to the satisfaction of the undersigned or an executive officer of Alberta Health Service, this order shall remain in effect.

Dated at Calgary Alberta, this 28th day of February 2011 confirming the verbal order issued on February 26th, 2011.



Tanya MacNeil
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244