

**IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA**  
**ORDER OF AN EXECUTIVE OFFICER**

**To: Stoneset Equity Development Corporation**  
**3915- 8 street SE**  
**Calgary, AB**  
**T2G 3A5**

**Re:** The drinking water supply located in Calgary, Alberta and municipally described as:

Symons Valley Ranch  
14555 Symons Valley Rd NW  
Calgary, AB

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The water sample collected after maintenance work on July 15<sup>th</sup>, 2011 revealed the presence of Total Coliforms.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Food Regulation, Alberta Regulation 31/2006, and Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The water sample collected on July 15, 2011 revealed the presence of Total Coliforms which is in contravention of the Food Regulation Section 17(1)(f)(i), which states “An operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial food establishment”.
- b. The water sample collected on July 15, 2011 revealed the presence of Total Coliforms which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted source of water is hereby declared **unfit for human consumption**;

ORDER OF AN EXECUTIVE OFFICER

Re: The Drinking Water System for Symons Valley Ranch located in Calgary, Alberta and municipally described as 14555  
Symons Valley Rd NW Calgary, Alberta

---

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
  - a. Post signage approved by Alberta Health Services at all water outlets accessible by the public stating that the water is not safe for human consumption.
  - b. Provide an approved hand sanitizer at all hand washing sinks for the disinfection of hands after they are washed.
  - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for at least one minute. This includes discontinuing the use of pop/juice fountains and ice machines supplied by the water source in question.
  - d. Ensure that all utensils, counter tops and food contact surfaces are cleaned and sanitized with an approved sanitizing step.
  - e. Conduct any necessary maintenance work on the existing drinking water system to rend the water safe for human consumption.
  - f. Submit two sets of bacteriological samples at least 24 hours apart, from representative locations, once the system has been adequately flushed.
2. The work referred to in paragraph 1(a) through 1(d) must be completed immediately.
3. The work referred to in paragraph 1(e) through 1(f) must be completed by August 1, 2011.
4. That, until such time as the work referred to in paragraph 1 is completed and the source of water is shown to be potable and the samples from paragraph 1(f) are satisfactory to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

**ORDER OF AN EXECUTIVE OFFICER**

**Re: The Drinking Water System for Symons Valley Ranch located in Calgary, Alberta and municipally described as 14555 Symons Valley Rd NW Calgary, Alberta**

---

Dated at Calgary, Alberta, this 18<sup>th</sup> day of July, 2011, confirming a verbal order issued on the 16<sup>th</sup> day of July, 2011.

---

Kenning Leung CPHI(C)  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.calgaryhealthregion.ca/envhealth](http://www.calgaryhealthregion.ca/envhealth)