

IN THE MATTER OF THE PUBLIC HEALTH ACT – ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Tim Horton Children's Ranch
1 Tim Horton Drive & Hwy. # 40
P.O. Box 117
Kananaskis, Alberta T0L 2H0

Tim Horton Children's Foundation, Inc
874 Sinclair Road
Oakville, Ontario L6K 2Y1

Andy Upwards
Property Manager
Tim Horton Children's Ranch
1 Tim Horton Drive & Hwy #40,
P.O.Box 117
Kananaskis, AB T0L 2H0

Re: The Drinking Water Supply located in Kananaskis, Alberta and municipally described as:

Tim Horton Children's Ranch
1 Tim Horton Drive & Hwy. # 40
P.O. Box 117
Kananaskis, Alberta

WHEREAS I, an **Executive Officer** of the **Alberta Health Services**, have inspected the above noted Drinking Water Supply pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- i. Water in the reservoirs and distribution system may be unsafe for human consumption as turbid water from a potentially contaminated well has been added to the water system.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Nuisance and General Sanitation Regulation (AR 243/200) exists in and about the above noted Drinking Water Supply, namely:

- i. Water in the reservoirs and distribution system may be unsafe for human consumption as turbid water from a potentially contaminated well has been added to the water system.

This is in breach of Section 11 of the Nuisance and General Sanitation Regulation.

AND WHEREAS by virtue of the foregoing, the above noted Source of Water is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue an Advisory to all users of the Drinking Water Supply of Tim Horton Children's Ranch to boil or treat the water to render it safe for human consumption, or to provide an alternate source of safe drinking water that is approved by Alberta Health Services, and
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:
 - a. Post boil water advisory signs next to all water fixtures that are accessible to the public. These signs must remain in place until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - b. Provide potable water from an approved source or provide water that has been boiled for one minute to patrons or staff until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - c. Provide hand sanitizer of at least 60% alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - d. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
 - e. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - f. Ensure that all dishes leaving the dishwasher must be air dried for at least four hours prior to use.
 - g. Ensure that after hand washing, food handlers are disinfecting hands with an alcohol based hand sanitizer of at least 60% alcohol content.
 - h. Conduct any necessary maintenance work on the drinking water system to render the water safe for human consumption.
 - i. Submit 2 water samples at least 24 hours apart to the Provincial Laboratory for Public Health (Microbiology) for bacteriological testing.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary

Southport Atrium
10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Cochrane

Cochrane Community
Health Centre
60 Grand Boulevard
Cochrane, AB T4C 2B9
Phone: 403-851-6172
Fax: 403-851-6009

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

3. The work referred to in **paragraph 2(a) – 2(g)** must be completed immediately and continue until rescinded by an Executive Officer.
4. The work referred to in **paragraph 2(h) – 1(i)** must be completed to the satisfaction of the undersigned or an executive officer of the Alberta Health Services by June 24, 2011.
5. That, until such time as the work referred to in **paragraph 2** is completed to the satisfaction of the undersigned, or an executive officer of the Alberta Health Services, and until such time as the water samples from **paragraph 2 (i)** are confirmed to be satisfactory, this order shall remain in effect.

Dated at Kananaskis, Alberta, this 22nd day of February, 2011 confirming the verbal order issued on the 14th day of February, 2011.

Lindsay Sullivan CPHI(C)
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers the Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Cochrane

Cochrane Community
Health Centre
60 Grand Boulevard
Cochrane, AB T4C 2B9
Phone: 403-851-6172
Fax: 403- 851-6009

Calgary

Southport Atrium
10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244