

ORDER OF AN EXECUTIVE OFFICER

To: Khalsa School Calgary
Calgary, Alberta

Khalsa School Calgary Educational Foundation
Calgary, Alberta

RE: The Drinking Water Supply located in Rocky View County, Alberta and municipally described as:

Khalsa School Calgary
245228 Range Road 284
Calgary, Alberta
T2M 4L5

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Drinking water cistern contaminated due to direct water contact with sewage effluent hose from septic hauling truck.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Drinking water cistern contaminated due to direct water contact with sewage effluent hose from septic hauling truck. which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issue an Advisory to all users of the Drinking Water Supply of Khalsa School Calgary to boil or treat the water to render it safe for human consumption, or to provide an alternate source of safe drinking water that is approved by Alberta Health Services, and
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted Drinking Water Supply, namely:

- a. Post unsafe for drinking purposes signs next to all water fixtures that are accessible to the public. These signs must remain in place until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - b. Disconnect or otherwise prevent access to all drinking water fountains.
 - c. Provide potable water from an approved source or provide water that has been boiled for one minute to patrons or staff until the drinking water is deemed safe for human consumption by an executive officer of the Alberta Health Services.
 - d. Provide hand sanitizer of at least 60% alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - e. Conduct any necessary maintenance work on the drinking water system to render the water safe for human consumption.
 - f. Submit 1 water sample to the Provincial Laboratory for Public Health (Microbiology) for bacteriological testing.
3. The work referred to in **paragraph 2(a) – 2(d)** must be completed immediately and continue until rescinded by an Executive Officer.
4. That, until such time as the work referred to in **paragraph 2(e)** is completed and the sample from **2(f)** is to be shown satisfactory and the source of water is shown to be potable to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Strathmore, Alberta, January 12, 2012

Norman Kruesel, CPHI(C)
Executive Officer
Environmental Health Officer

YOU HAVE THE RIGHT TO APPEAL

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at 24th Floor, Telus Plaza, 10025 - Jasper Avenue, Edmonton, Alberta, T5J 1S6 Telephone (780) 427-2813.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at (780) 342-0122 or the Public Health Appeal Board (780) 427-2813.

You are advised that all orders remain in effect pending such an appeal

HEALTH LEGISLATION, REGULATIONS AND STANDARDS

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7) or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health & Wellness at (780) 427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

Confirmation of an oral order issued to Mike Simms, at January 9, 2012.

AIRDRIE Regional Health Centre

604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

BANFF Health Unit

303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

CALGARY - Southport Atrium

10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

CANMORE Public Health

#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

CLARESHOLM Public Health

5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

COCHRANE Community Health Centre

60 Grande Boulevard
Cochrane, AB T4C 0S4
Phone: 403-851-6000
Fax: 403- 851-6009

OKOTOKS Health and Wellness Centre

11 Cimarron Common
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

STRATHMORE Public Health Office

650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.albertahealthservices.ca/eph.asp