

IN THE MATTER OF THE PUBLIC HEALTH ACT - ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Fiona & Lonny Middleton
705 Benchlands Trail
Canmore, Alberta T1W 3G9

Re: The Swimming Pool located in Canmore, Alberta and municipally described as:

A Bear and Bison Country Inn
705 Benchlands Trail
Canmore, Alberta T1W 3G9

WHEREAS I, an **Executive Officer** of the **Calgary Health Region**, have inspected the above noted swimming pool pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted swimming pool which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Bacteriological water samples are not being collected and submitted to the Provincial Laboratory at appropriate intervals. No water samples have been submitted for bacteriological analysis since November 5, 2007.

AND WHEREAS such inspection disclosed that the following breaches of the **Public Health Act** and the **Swimming Pool, Wading Pool, and Water Spray Park Regulation**, Alberta Regulation 293/2006 exist in and about the above noted swimming pool, namely:

- a. Bacteriological water samples are not being collected and submitted to the Provincial Laboratory at appropriate intervals. This is in contravention of section 15 (1) of the Swimming Pool, Wading Pool, and Water Spray Park Regulation, which states that "Every week a sample of the water in a pool must be taken and submitted to the Provincial Laboratory of Public Health (Microbiology) for microbiological testing."

AND WHEREAS by virtue of the foregoing, the above noted premises are hereby declared to be **closed**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner **immediately close** the above noted swimming pool and secure it from unauthorized entry.
2. That the Owner undertake and diligently pursue the completion of the following work in and

about the above noted swimming pool, namely:

- a. Submit water samples for bacteriological analysis every week of operation to the Provincial Laboratory of Public Health (Microbiology) for microbiological testing.
3. That until such time as a water sample from paragraph 2a is confirmed to be satisfactory, the above noted swimming pool shall remain closed and secured from unauthorized entry.

Dated at Canmore, Alberta, this 24 day of January, 2008.

Lindsay Sullivan
Executive Officer
Calgary Health Region

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers the Calgary Health Region to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Calgary Health Region, Centre 15
1509 Centre Street SW
Calgary, AB T2G 2E6
Phone: 403-943-8060
Fax: 403-943-8090

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Bag 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-934-3454
Fax: 403-934-3827