

IN THE MATTER OF THE PUBLIC HEALTH ACT - ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Ramada Inn & Suites
191 East Lake Crescent
Airdrie, AB T4A 2H7

Re: The swimming pool located in Airdrie, Alberta and municipally described as:

Ramada Inn & Suites
191 East Lake Crescent
Airdrie, AB T4A 2H7

WHEREAS I, an **Executive Officer** of the **Calgary Health Region**, have inspected the above-noted swimming pool pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above-noted swimming pool which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The presence of Total Coliforms in two consecutive microbiological samples collected on February 13, 2009, and February 18, 2009.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Swimming Pool, Wading Pool and Water Spray Park Regulation, Alberta Regulation 293/2006 exist in and about the above-noted swimming pool, namely:

The presence of Total Coliforms in two microbiological samples collected on February 13, 2009, and February 18, 2009. This is in contravention of Section 16(c), which states that "the quality of water in a pool must be maintained so that samples of the water do not show the presence of coliforms in a 100 mL sample".

AND WHEREAS by virtue of the foregoing, the above noted premises are hereby declared to be **closed**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner **immediately close** the above-noted swimming pool and secure it from unauthorized entry.
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above-noted swimming pool, namely:

ORDER OF AN EXECUTIVE OFFICER

Re: The Swimming Pool located in Airdrie, Alberta and municipally described as 191 East Lake Crescent, Airdrie, Alberta

- a. Treat the swimming pool water to eliminate any possible source of contamination and then chemically balance the swimming pool.
 - b. Submit a water sample for bacteriological analysis to the Provincial Laboratory of Public Health (Microbiology) for microbiological testing.
3. That until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of the Calgary Health Region, and until such time as a water sample from paragraph 2b is confirmed to be satisfactory, the above-noted swimming pool shall remain closed and secured from unauthorized entry.

Dated at Airdrie, Alberta, this 24th day of February, 2009, confirming a Verbal Order given on February 23, 2009.

Carol Brittain, BSc, CPHI(C)
Executive Officer
Calgary Health Region

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers the Calgary Health Region to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

Airdrie
Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff
Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View
Calgary Health Region, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore
Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm
Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury
Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks
Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore
Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.calgaryhealthregion.ca/envhealth