

IN THE MATTER OF THE PUBLIC HEALTH ACT - ALBERTA  
ORDER OF AN EXECUTIVE OFFICER

To: David English  
5544 Dalhousie Dr NW  
Calgary, Alberta T3A 1P9  
(the "Owner")

Teri Collins-English  
5544 Dalhousie Dr NW  
Calgary, Alberta T3A 1P9  
(the "Owner")

Re: The Whirlpool located in Calgary, Alberta and municipally described as:

English Bed and Breakfast Whirlpool  
5544 Dalhousie Dr NW  
Calgary, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted whirlpool pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted whirlpool which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. The presence of Total Coliforms in two consecutive microbiological samples collected on July 21, 2009 and July 29, 2009.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Swimming Pool, Wading Pool and Water Spray Park Regulation, Alberta Regulation 293/2006 exist in and about the above noted swimming pool, namely:

- a. The presence of Total Coliforms in two consecutive microbiological samples collected on July 21, 2009 and July 29, 2009. This is in contravention to Section 16 (c) of the Regulation.

AND WHEREAS by virtue of the foregoing, the above noted premises are hereby declared to be **closed**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner **immediately close** the above noted whirlpool and secure it from

unauthorized entry.

2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted whirlpool, namely:
  - a. Treat the whirlpool to remove all contaminants.
  - b. Submit a water sample to the Provincial Laboratory for bacteriological testing.
3. That until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, and the water sample submitted under paragraph 2b is confirmed to be satisfactory, the above noted whirlpool shall remain closed and secured from unauthorized entry.

Dated at Calgary, Alberta, this 31st day of July, 2009.

---

Melissa Chandler, CPHI (C)  
Executive Officer  
Alberta Health Services

***Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24<sup>th</sup> Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.***

***The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.***

---

**Airdrie**

Airdrie Public Health Centre  
604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**Banff**

Banff Health Centre  
303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**Calgary/Mountain View/Rocky View**

Alberta Health Services, *Southport*  
10101 Southport Rd SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**Canmore**

Canmore Public Health  
#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**Claresholm**

Claresholm Public Health  
5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403-625-4061  
Fax: 403-625-4062

**Didsbury**

Didsbury Health Unit  
PO Box 130  
1210 -20th Avenue  
Didsbury, AB T0M 0W0  
Phone: 403-335-7292  
Fax: 403-335-7610

**Okotoks**

Okotoks Public Health Centre  
11 Cimarron Commons  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**Strathmore**

Public Health Building  
650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244