

IN THE MATTER OF THE PUBLIC HEALTH ACT - ALBERTA
ORDER OF AN EXECUTIVE OFFICER

To: Triple Diamond Ranches Ltd.
Box 486
Cochrane, Alberta T4C 1A7
(the "**Owner**")

Rhonda Turco
Box 486
Cochrane, Alberta T4C 1A7
(the "**Owner**")

Bud Robinson
Box 486
Cochrane, Alberta T4C 1A7
(the "**Owner**")

Re: The Whirlpool located in the County of Rocky View, Alberta and municipally described as:

Triple Diamond R.V. Park - Outdoor Whirlpool
NW 10 28 05 W5M

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted whirlpool pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted whirlpool which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Consecutive water samples submitted on June 28 and July 6, 2010 revealed the presence of *Pseudomonas aeruginosa*.
- b. The automated chemical feeding and monitoring system for pH and chlorine is not operating in a proper and consistent manner.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Swimming Pool, Wading Pool and Water Spray Park Regulation, Alberta Regulation 293/2006 exist in and about the above noted whirlpool, namely:

- a. Consecutive water samples submitted on June 28 and July 6, 2010 revealed the presence of *Pseudomonas aeruginosa*. This is in contravention to Section 16(b) of the Regulation.

ORDER OF AN EXECUTIVE OFFICER

Re: The Whirlpool located in the County of Rocky View, Alberta and municipally described as Triple Diamond RV Park Outdoor Whirlpool, NW 10-28-05-W5M, County of Rocky View, Alberta

- b. The automated chemical feeding and monitoring system for pH and chlorine is not operating in a proper and consistent manner. This is in contravention to Section 12(2) of the Regulation.

AND WHEREAS by virtue of the foregoing, the above noted premises are hereby declared to be **closed**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner **immediately close** the above noted whirlpool and secure it from unauthorized entry.
2. That the Owner undertake and diligently pursue the completion of the following work in and about the above noted whirlpool, namely:
 - a. Treat the whirlpool so that the water is microbiologically, chemically and physically safe for use.
 - b. Conduct the necessary repairs to the automated chemical feeding and monitoring system so that it is maintained in good working condition.
 - c. Submit a water sample to the Provincial Laboratory of Public Health (Microbiology) for microbiological testing.
3. That until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, and a water sample from 2(c) is satisfactory, the above noted whirlpool shall remain closed and secured from unauthorized entry.

Dated at Calgary, Alberta, this 12th day of July, 2010, confirming a verbal order issued on the 9th day of July, 2010.

Grace Mar, CPHI(C)
Executive Officer
Alberta Health Services

Section 5(2) of the Public Health Act provides that a person who is directly affected by this Order and considers himself or herself aggrieved hereby may appeal the same to the Public Health Appeal Board, 24th Floor, Telus Plaza North Tower, 10025 Jasper Avenue, Edmonton AB T5J 2N3, within ten (10) days. The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal.

The Owner is advised that the Public Health Act empowers Alberta Health Services to carry out the terms of this Order on the Owner's behalf and at the Owner's expense should the Owner fail to comply with the terms hereof.

ORDER OF AN EXECUTIVE OFFICER

Re: The Whirlpool located in the County of Rocky View, Alberta and municipally described as Triple Diamond RV Park Outdoor Whirlpool, NW 10-28-05-W5M, County of Rocky View, Alberta

Airdrie

Airdrie Public Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

Banff

Banff Health Centre
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

Calgary/Mountain View/Rocky View

Alberta Health Services, *Southport*
10101 Southport Rd SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

Canmore

Canmore Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

Claresholm

Claresholm Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403-625-4061
Fax: 403-625-4062

Didsbury

Didsbury Health Unit
PO Box 130
1210 -20th Avenue
Didsbury, AB T0M 0W0
Phone: 403-335-7292
Fax: 403-335-7610

Okotoks

Okotoks Public Health Centre
11 Cimarron Commons
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

Strathmore

Public Health Building
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.calgaryhealthregion.ca/envhealth

INACTIVE