

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: 352002 Alberta Ltd.
Andrew Brassard

Darrel Zakreski

Craig Sallans (Manager)

RE: The whirlpool located in Calgary, Alberta and municipally described as:
Goliath's
308 17 Avenue SW
Calgary AB
T2S 0A8

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Bacteriological water samples taken on November 11, 2011, November 15, 2011, and November 24, 2011 had *Pseudomonas aeruginosa* isolated.
- b. Current pool maintenance staff have not taken an approved pool operator's course.
- c. The current main drain cover does not meet anti-entrapment provisions.
- d. Detailed records of water chemistry are not being maintained.
- e. The pump room is dirty and chemicals are in disarray.
- f. Floor tiles are missing in some of the common areas.
- g. There is no recollection or documentation of the last time the filter media has been changed.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Swimming Pool, Wading Pool and Water Spray Park Regulation, Alberta Regulation 293/2006 exist in and about the above noted swimming pool, namely:

- a. Bacteriological water sample taken on November 11, 2011, November 15, 2011, and November 24, 2011 had *Pseudomonas aeruginosa* isolated. This is in contravention of Section 16 of the Swimming Pool, Wading Pool and Spray Park Regulation.
- b. Current pool maintenance staff have not taken an approved pool operator's course. This is in contravention of Section 7(2) of the Swimming Pool, Wading Pool and Spray Park Regulation.
- c. The current main drain cover does not meet anti-entrapment provisions. This is in contravention to Section 19(1) of the Swimming Pool, Wading Pool, and Spray Park Regulation.

- d. Detailed records of water chemistry are not being maintained. This is in contravention to Section 14 of the Swimming Pool, Wading Pool, and Spray Park Regulation.
- e. The pump room is dirty and chemicals are in disarray. This is in contravention to Section 22(b) of the Swimming Pool, Wading Pool, and Spray Park Regulation.
- f. Floor tiles are missing in some of the common areas. This is in contravention to Section 22(a)(i) of the Swimming Pool, Wading Pool, and Spray Park Regulation.
- g. There is no recollection or documentation of the last time the filter media has been changed. This is in contravention to Section 9(1)(b) of the Swimming Pool, Wading Pool, and Spray Park Regulation.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted whirlpool.
2. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Treat the whirlpool water to eliminate any possible source of contamination and then chemically balance the pool.
 - b. Maintain a log book for all water quality tests, including daily tests of free available chlorine, combined available chlorine, pH, alkalinity, as well as the readings from the monitoring system, and recording any steps that were taken to maintain water quality.
 - c. Install drain cover that meets the ASME standard for anti-entrapment.
 - d. Submit a bacteriological sample to the Provincial Lab.
 - e. Replace the missing floor tiles in the common areas.
 - f. Clean and organize the pump room.
 - g. Replace the current sand in the filter.
 - h. Pool operator must successfully complete a pool operator's course approved by the Executive Officer.
3. That until such time as the work stated above are completed to the satisfaction of an Executive Officer of Alberta Health Services, and a satisfactory bacteriological sample result has been confirmed from the Provincial Lab, the above noted whirlpool shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, December 05, 2011.

Salima Kassam BTech, CPHI(C)
Executive Officer
Environmental Health Officer

YOU HAVE THE RIGHT TO APPEAL

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at 24th Floor, Telus Plaza, 10025 - Jasper Avenue, Edmonton, Alberta, T5J 1S6 Telephone (780) 427-2813.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at (780) 342-0122 or the Public Health Appeal Board (780) 427-2813.

You are advised that all orders remain in effect pending such an appeal

HEALTH LEGISLATION, REGULATIONS AND STANDARDS

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7) or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health & Wellness at (780) 427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

Confirmation of an oral order issued to Craig Sallans on November 28, 2011.

AIRDRIE Regional Health Centre

604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

BANFF Health Unit

303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

CALGARY - Southport Atrium

10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

CANMORE Public Health

#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

CLARESHOLM Public Health

5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

COCHRANE Community Health Centre

60 Grande Boulevard
Cochrane, AB T4C 0S4
Phone: 403-851-6000
Fax: 403- 851-6009

OKOTOKS Health and Wellness Centre

11 Cimarron Common
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

STRATHMORE Public Health Office

650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.albertahealthservices.ca/eph.asp

INACTIVE