

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: City of Calgary – Parks & Recreation
Joe Moore (Aquatics Coordinator)

Erin Fox (Supervisor)
Highwood Outdoor Pool

Highwood Community Association

RE: The swimming pool located in Calgary, Alberta and municipally described as:
Highwood Outdoor Pool
25 Holmwood Avenue NW
Calgary, Alberta
T2K 6J1

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. Bacteriological water sample taken on June 29, 2011 had a heterotrophic plate count of 330 colony forming units/mL.
- b. Bacteriological water sample taken on July 5, 2011 had a heterotrophic plate count of 940 colony forming units/mL.
- c. Bacteriological water sample taken on July 12, 2011 had a heterotrophic plate count of 5820 colony forming units/mL.
- d. Bacteriological water sample taken on July 19, 2011 had a heterotrophic plate count of 1180 colony forming units/mL.
- e. Bacteriological water sample taken on July 26, 2011 had a heterotrophic plate count of 11,970 colony forming units/mL.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Swimming Pool, Wading Pool and Water Spray Park Regulation, Alberta Regulation 293/2006 exist in and about the above noted swimming pool, namely:

- a. Bacteriological water sample taken on June 29, 2011 had a heterotrophic plate count of 330 colony forming units/mL. This is in contravention of Section 16(a) of the Swimming Pool, Wading Pool and Spray Park Regulation.
- b. Bacteriological water sample taken on July 5, 2011 had a heterotrophic plate count of 940 colony forming units/mL. This is in contravention of Section 16(a) of the Swimming Pool, Wading Pool and Spray Park Regulation.

- c. Bacteriological water sample taken on July 12, 2011 had a heterotrophic plate count of 5820 colony forming units/mL. This is in contravention of Section 16(a) of the Swimming Pool, Wading Pool and Spray Park Regulation.
- d. Bacteriological water sample taken on July 19, 2011 had a heterotrophic plate count of 1180 colony forming units/mL. This is in contravention of Section 16(a) of the Swimming Pool, Wading Pool and Spray Park Regulation.
- e. Bacteriological water sample taken on July 26, 2011 had a heterotrophic plate count of 11,970 colony forming units/mL. This is in contravention of Section 16(a) of the Swimming Pool, Wading Pool and Spray Park Regulation.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the Owner immediately close the above noted swimming pool.
- 2. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Treat the swimming pool water to eliminate any possible source of contamination and then chemically balance the pool.
 - b. Submit a bacteriological sample to the Provincial Lab.
- 3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services, and a satisfactory bacteriological sample has been received from the Provincial Lab, the above noted swimming pool shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, August 3, 2011.

Sarah Yusuf, B.Sc., BEH, CPHI(C)
Executive Officer
Environmental Health Officer

YOU HAVE THE RIGHT TO APPEAL

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at 24th Floor, Telus Plaza, 10025 - Jasper Avenue, Edmonton, Alberta, T5J 1S6 Telephone (780) 427-2813.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at (780) 342-0122 or the Public Health Appeal Board (780) 427-2813.

You are advised that all orders remain in effect pending such an appeal

HEALTH LEGISLATION, REGULATIONS AND STANDARDS

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7) or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health & Wellness at (780) 427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

Confirmation of an oral order issued to Erin Fox on July 29, 2011.

AIRDRIE Regional Health Centre
604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

BANFF Health Unit
303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

CALGARY - Southport Atrium
10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

CANMORE Public Health
#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

CLARESHOLM Public Health
5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

COCHRANE Community Health Centre
60 Grande Boulevard
Cochrane, AB T4C 0S4
Phone: 403-851-6000
Fax: 403-851-6009

OKOTOKS Health and Wellness Centre
11 Cimarron Common
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

STRATHMORE Public Health Office
650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244